

Addendum 1

DATE: October 30, 2019

ITEM: BID – Submersible Pumps and Related Materials

This addendum is issued to make a correction to page 2 of the advertisement and to answer questions pertaining to the above Bid.

1. On page 2, paragraph 2 should read:

Bids shall be addressed to the St. John the Baptist Parish Purchasing and Procurement. Bid envelopes shall be sealed, display the name and address of the bidder, and be clearly marked on the outside of the envelope **“2020 Sewer Submersible Pumps and Related Materials.”** Any bids received after the specified time and date will not be considered. The sealed bids will be publicly opened and **read aloud** at 3:00 o'clock p. m. November 13, 2019 in the St. John the Baptist Parish Government Complex Council Chambers located at 1811 W. Airline Highway, LaPlace, LA 70068.

2. Question: Ref. 16 lists a Shut Off Head of 1,100ft. Is this an error?

Answer: Yes, it should read 100 ft.