


ADDENDUM NO. 3

Pleasure Bend Water System St. John the Baptist Parish, Louisiana

DATE ISSUED: July 19, 2017
BID DATE: July 25, 2017

EES PROJECT NO. 1520

This Addendum shall be considered as included and/or amended in the original Contract Documents and shall take precedence over any part of the original documents or previous addendum in conflict therewith. This Addendum contains 1 page. All bidders shall ensure all sheets of this Addendum are enclosed. If sheets are missing from this Addendum, it is the responsibility of the Bidder to notify the Engineer seventy-two (72) hours prior to the bid date and time.



I. SPECIFICATIONS

A. Section 02521 – Potable Water Bolted Steel Ground Storage Tank

In paragraph 1.04 Acceptable Manufacturers on page 02521-1, **change** the paragraph to read as follows:

“The steel tank and accessories shall be as manufactured by Superior Tank Company of Rosenberg, TX; American Tank of New Iberia, LA; CST Industries of Kansas City, MO; or approved equal.”

II. DRAWINGS

A. Sheet M07

In Section A, **replace** “8” flange plug valve w/ electric actuator” with “8” flange plug valve w/ hand wheel operator”.

Engineer’s Note: Plug valve at this location shall be manually operated. No power is required at tie-in location.