

PUMP STATION INFORMATION SCHEDULE

SHEET NUMBER **E2.0**

BASE/ALT BID (NOTE 1)	STATION NUMBER	LOCATION NAME	POLE SITE (NOTE 2)	PUMP RUN TIME	MOTOR/PUMP FAIL	AUTO SHUT OFF	LEVELS	STATION PROBLEM ALARM	DRY WELL FAIL/FLOOD	DUPLEX CONTROL	QUADPLEX CONTROL	TOUCH SCREEN (NOTE 3)	PUMP SIZE	STATION LONGITUDE	STATION LATITUDE	TREATMENT PLANT
2	0	MCREINE TRAILER PARK		•	•	•	•	•		•			2-4" 5 HP PUMPS	-90.461241	30.05319	RIVER ROAD/WOODLAND WWTP
B	1	BROOKS PRODUCTS	•	•	•	•	•	•	•			•	2-4" 20 HP PUMPS	-90.467583	30.053465	RIVER ROAD/WOODLAND WWTP
1	2	RIVER FOREST - WINDSOR #1		•	•	•	•	•		•			2-6" 20 HP PUMPS	-90.461118	30.056998	RIVER ROAD/WOODLAND WWTP
3	3	RIVER FOREST - LANCELOT #1		•	•	•	•	•		•			2-4" 10 HP PUMPS	-90.443569	30.060612	RIVER ROAD/WOODLAND WWTP
B	4	ROUSSEL'S	•	•	•	•	•	•			•	•	2-6" 20 HP & 1-6" 30 HP PUMPS	-90.476648	30.066137	RIVER ROAD/WOODLAND WWTP
B	5	NED DUHE	•	•	•	•	•	•			•	•	3-4" 40 HP PUMPS	-90.619762	30.058901	GARYVILLE WWTP
2	6	EAST 7TH ST		•	•	•	•	•		•			2-6" 15 HP PUMPS	-90.542656	30.041109	TIGERVILLE WWTP
3	7	SIDNEY VICKNAIR TRACT		•	•	•	•	•		•			2-4" 7.5 HP PUMPS	-90.458395	30.052005	RIVER ROAD/WOODLAND WWTP
1	8	BELL SOUTH		•	•	•	•	•		•			2-4" 15 HP PUMPS	-90.482128	30.066656	RIVER ROAD/WOODLAND WWTP
2	9	MAIN ST - ST MATHEWS CHURCH		•	•	•	•	•		•			2-4" 10 HP PUMPS	-90.471189	30.072392	RIVER ROAD/WOODLAND WWTP
3	10	JENNIFER LN & MAIN ST		•	•	•	•	•		•			2-4" 10 HP PUMPS	-90.468153	30.07417	RIVER ROAD/WOODLAND WWTP
3	11	REMY SUBDIVISION		•	•	•	•	•		•			2-4" 10 HP PUMPS	-90.462561	30.077452	RIVER ROAD/WOODLAND WWTP
1	12	WOODLAND #2		•	•	•	•	•		•			2-4" 15 HP PUMPS	-90.451196	30.087563	WOODLAND WWTP
1	13	INDIGO PARK		•	•	•	•	•		•			2-6" 10 HP PUMPS	-90.461266	30.089126	WOODLAND WWTP
1	14	WOODLAND #5		•	•	•	•	•		•			2-8" 50 HP PUMPS	-90.46267	30.092247	WOODLAND WWTP
B	15	CAMBRIDGE #1	•	•	•	•	•	•				•	2-8" 60 HP & 2-6" 60 HP PUMPS	-90.469817	30.093123	WOODLAND WWTP
B	16	LOVER'S LANE	•	•	•	•	•	•				•	2-6" 15 HP PUMPS	-90.476751	30.091164	WOODLAND WWTP
2	17	CAMBRIDGE 3		•	•	•	•	•		•			2-6" 30 HP PUMPS	-90.475375	30.084725	WOODLAND WWTP
3	18	CAMBRIDGE #5		•	•	•	•	•		•			2-4" 10 HP PUMPS	-90.484612	30.073586	WOODLAND WWTP
1	19	CARROLLWOOD DR		•	•	•	•	•		•			2-6" 15 HP PUMPS	-90.494748	30.078144	WOODLAND WWTP
2	20	GREENWOOD #2		•	•	•	•	•		•			2-3" 5 HP PUMPS	-90.48607	30.079679	WOODLAND WWTP
1	21	HEMLOCK ST		•	•	•	•	•	•	•			2-4" 7.5 HP PUMPS	-90.49639	30.071933	RIVER ROAD WWTP
B	22	PARISH BUILDING	•	•	•	•	•	•			•	•	3-8" 60 HP & 1-10" 60 HP PUMPS	-90.500686	30.071407	RIVER ROAD WWTP
1	23	CARMEL VALLEY		•	•	•	•	•		•			2-4" 10 HP PUMPS	-90.490679	30.089249	RIVER ROAD WWTP
1	24	COUNTRY CLUB #1		•	•	•	•	•		•			2-4" 15 HP PUMPS	-90.488929	30.089445	WOODLAND WWTP
1	25	PEBBLE BEACH		•	•	•	•	•	•	•			2-4" 7.5 HP PUMPS	-90.49821	30.091854	RIVER ROAD WWTP
B	26	BIG BELLE TERRE	•	•	•	•	•	•				•	2-8" 40 HP PUMPS	-90.498975	30.085914	RIVER ROAD WWTP
1	27	ELM ST		•	•	•	•	•		•			2-6" 15 HP PUMPS	-90.501266	30.068576	RIVER ROAD WWTP
2	28	LAPLACE PARK #1		•	•	•	•	•		•			2-4" 30 HP PUMPS	-90.510215	30.082113	RIVER ROAD WWTP
2	29	MINI STORAGE		•	•	•	•	•		•			2-4" 10 HP PUMPS	-90.52495	30.07854	RIVER ROAD WWTP
2	30	BELLE POINT SOUTH #1		•	•	•	•	•		•			2-6" 15 HP PUMPS	-90.523306	30.075419	BELLE POINTE WWTP
2	31	HOSPITAL		•	•	•	•	•		•			2-4" 7.5 HP PUMPS	-90.514182	30.073358	
B	32	EAST 10TH ST	•	•	•	•	•	•			•	•	3-6" 20 HP PUMPS	-90.546339	30.057585	RIVER ROAD WWTP
B	33	DUPONT	•	•	•	•	•	•				•	2-12" 300 HP PUMPS	-90.533665	30.062417	RIVER ROAD WWTP
B	34	ZA MONTZ	•	•	•	•	•	•			•	•	2-8" 200 HP & 1-8" 30 HP PUMPS	-90.551101	30.078767	RIVER ROAD WWTP
B	35	CENTRAL AVE	•	•	•	•	•	•				•	2-6" 50 HP PUMPS	-90.552673	30.070827	RIVER ROAD WWTP
3	36	RIVERSIDE ACADEMY		•	•	•	•	•		•			2-6" 20 HP PUMPS	-90.559265	30.061256	RIVER ROAD WWTP
3	37	WEST 10TH ST		•	•	•	•	•		•			2-6" 10 HP PUMPS	-90.564284	30.069927	RIVER ROAD WWTP
3	38	ROSENWALD ST		•	•	•	•	•		•			2-6" 10 HP PUMPS	-90.572023	30.076539	RIVER ROAD WWTP
3	39	NORTHWEST 12TH ST		•	•	•	•	•		•			2-6" 30 HP PUMPS	-90.565679	30.074567	RIVER ROAD WWTP
2	40	WEST 19TH		•	•	•	•	•		•			2-6" 15 HP PUMPS	-90.577948	30.060397	RIVER ROAD WWTP
2	41	TIMBERMILL		•	•	•	•	•		•			2-4" 10 HP PUMPS	-90.621246	30.062643	GARYVILLE WWTP
2	42	SOUTH CHURCH & BLACKBERRY		•	•	•	•	•		•			2-4" 6 HP PUMPS	-90.618435	30.044584	GARYVILLE WWTP
2	43	WEST 8TH ST		•	•	•	•	•		•			2-6" 20 HP PUMPS	-90.665821	30.040546	WALLACE WWTP
2	44	JACK CT		•	•	•	•	•		•			2-6" 20 HP PUMPS	-90.656011	30.045958	WALLACE WWTP
3	45	HWY 18 NEAR PERCY CT		•	•	•	•	•		•			2-6" 15 HP PUMPS	-90.598443	30.040188	CENTRAL WWTP
3	46	WEST 1ST ST		•	•	•	•	•		•			1-4" 15 HP & 2-4" 7.5 HP PUMPS	-90.590528	30.035995	CENTRAL WWTP
3	47	CENTRAL AVE		•	•	•	•	•		•			2-4" 7.5 HP PUMPS	-90.58291	30.034708	CENTRAL WWTP
3	48	GEORGE CT		•	•	•	•	•		•			2-6" 20 HP PUMPS	-90.536377	30.041279	TIGERVILLE WWTP
3	49	EAST 13TH		•	•	•	•	•		•			2 5 HP PUMPS	-90.507505	30.044696	TIGERVILLE WWTP

SHEET E2.0 NOTES:

1. REFERENCE SHEET E1.0 AND SPECIFICATIONS FOR BASE BID AND ALTERNATES. IN THIS SCHEDULE ITEMS ARE INDICATED AS FOLLOWS: B = BASE BID, 1 = ALTERNATE 1, 2 = ALTERNATE 2, 3 = ALTERNATE 3.
2. THIS STATION IS A MASTER STATION AND SHALL BE GIVEN PRIORITY FOR THE DESIGN/INSTALLATION OF POLES NEEDED TO TRANSMIT DATA TO WATER TOWER WIRELESS REPEATER.
3. THIS STATION IS A MASTER STATION AND SHALL INCLUDE A TOUCH SCREEN MMI AS DESCRIBED ELSEWHERE IN THE DRAWINGS AND THE SPECIFICATIONS.



XREF:

DATE:

FILE NAME: NO.13.060-E2.0

WASTEWATER LIFT STATION TELEMETRY SYSTEM FOR ST. JOHN THE BAPTIST PARISH, LOUISIANA SCHEDULES AND DETAILS

BKJ BURK-KLEINPETER, INC.
ENGINEERS, ARCHITECTS, PLANNERS, ENVIRONMENTAL SCIENTISTS
4176 CANAL STREET, NEW ORLEANS, LA 70119-5994
PHONE (504)486-5901 • FAX (504)486-1714
BKJ PROJECT NUMBER NO.13.060

DESIGNED: B.M.
CHECKED: P.H.
DATE: 11/20/14
REVISION DESCRIPTION: NO. OF SHEET

NO.	DATE	BY